## **Environmental and Economic Characteristics**

## **Biodiesel and Cold Climate Heat Pumps**





PHOTO A. A B100-fired boiler in a Brookhaven Nationa Laboratorv testing facility.

Ray Albrecht, P.E.

**Technical Representative National Biodiesel Board** 

Member of ISO New England Planning Advisory Committee









#### Independent System Operators regulated by FERC



Each ISO has about 10 individual control zones for operations.



Complex grid network with central control system for dispatch and pricing of power.





## **Types of Fuel-fired Power Generation Systems**



Steam cycle has about 30% steady-state efficiency with slow start capability. Old technology but still commonly used.

0.7 to 0.9 tons CO2 per MWh for Natural Gas/Oil



Continued-cycle generation process

Combustion turbines range in steady-state efficiency from 20% up to 40%. Can ramp up relatively fast (10 minutes to 2 hours) but high fuel consumption and NOx emissions at start-up plus efficiency loss at less than full load.

0.6 to 1.2 tons CO2 per MWh for Natural Gas/Oil

Combined cycle can have up to 60% max steadystate efficiency but only moderate ramp-up capability (usually 1 or 2 hours) and long period of high NOx emissions during start-up.

0.4 to 0.6 tons CO2 per MWh for Natural Gas/Oil

## **Energy Sources for Power Generation in New England**



Long way to go for solar PV and wind power to displace natural gas in marginal operation.

Figure 7-1: New England's generator winter seasonal claimed capability (MW, %) and annual electric energy production (GWh, %) by fuel type for 2018.

Natural gas is dominant fuel. Nuclear only 3300 MW capacity due to retirement of Pilgrim station but runs 24/7 as base load. Oil-fired generation has substantial capacity but used only during severe grid peak loads. MSW and wood-fired generation significant but not growing. Solar PV and wind power growing steadily but with intermittent output.

## Natural Gas Spot Market Price Vs. Outdoor Temperature



Pipeline constraints limit natural gas availability in Northeast during cold weather. Spot market prices start to climb at about 30 deg F. Power plants required to purchase natural gas only in spot market not via firm price contracts. Fuel cost about 80% of LMP. High fuel cost = high electricity cost. ISO New England Example Graph of Wholesale Price Vs. Grid Load



Prices determined via auctions at 1 hr and 5 minute intervals.

All generators earn same market clearing price determined by highest successful bidder.

Level of curve beyond 5,000 MW depends on spot market price of natural gas.

Slope of price curve becomes steeper at higher grid load due to lower efficiency of generator at margin plus short duration of extreme peaks thus greater impact of fuel consumption during start-up.

#### ISO New England Example Hourly Load and Price Graphs

Moderate Cold Weather – February 4, 2019



Peak grid loads = peak wholesale prices

Early morning and evening peaks just under 18,000 MW. Peak pricing of just under \$80 per MWh.

Existing peak grid loads already the result of electric heating and range from 15,000 to over 20,000 MW during the winter.

#### ISO New England Weekly Average Prices for Wholesale Power



Highest prices occur during winter months.

Cumulative sum of wholesale prices determine average supply charges on customer bills.

Peak power prices hidden from customers.

Many utility and State agency calculations of heat pump savings use average annual prices for electricity instead of monthly values.

Winter prices for wholesale power will continue to rise with added thermal loads.

Everybody pays the higher prices.

#### Single Family Home in New England

### Moderate Winter Day



Simple-cycle generation during peak periods.

Combined-cycle generation during off-peak periods.

#### Single Family Home in New England

**Cold Winter Day** 



Oil-fired steam-cycle generation at margin during evening peak of about 21,000 MW.

MER shows steps from gas-fired combined cycle to gas-fired simple-cycle to oil-fired generation then back to gas-fired simple-cycle.

**Single Family Home in New England** 



First step of analysis includes determination of heat pump COP vs. outdoor temperature.

Data above are based on multiple field testing studies not manufacturer ratings.

Single Family Home in New England

#### **Moderate Winter Day**



Heat pump carbon intensity approximately the same as B50 but with variations due to peak and off-peak power generation MERs.

B100 still the lowest carbon option vs. cold-climate heat pump.

Single Family Home in New England

**Cold Winter Day** 



Heat pump shows higher carbon intensity than ULSD except during overnight hours due to lower COPs and higher generation MER.

### ISO New England – Impact of Increasing Grid Load



Total offshore wind power production of 35 million MWh necessary during December to March to provide for residential heat pump operation.

**27,000** MW of offshore wind nameplate capacity necessary at 45% winter capacity factor. Several times higher than MA/CT/RI offshore wind capacity goals.

Add 50% for commercial/industrial/institutional thermal loads. Problem gets worse.

## Looking to the Future

#### CO2 Emissions (tons per year) for a Typical Single Family Home

	2020	2030	2040	2050
ULSD	8.0	8.0	8.0	8.0
B20	6.8	6.6	6.5	6.4
B50	4.8	4.6	4.4	4.0
Cold-Climate Heat Pump	5.0 ?	???	???	1.0 ?
B100	1.6	1.2	0.8	0.0

B50 and heat pumps competitive during next ten to fifteen years .

Cold-climate heat pump CO2 emissions dependent on hourly grid Marginal Emission Rates plus achievement of high levels of new renewable generation capacity.

## Biodiesel-fired Boilers and Electric Heat Pumps Typical NOx Emission Factors lbs per MMBTU Delivered Heat



PHOTO A. A B100-fired boiler in a Brookhaven National Laboratory testing facility.



FIGURE 3. Emissions that occurred during the transition from No. 2 heating oil to B100



	Steady-state	4 hr Peak Load
Combined Cycle w/SCR and OC (5 ppm @ 15% O2)	0.02 lb per MMBTU	0.15 lb per MMBTU
Combustion Turbine w/SCR and OC (5 ppm @ 15% O2)	0.03 lb per MMBTU	0.25 lb per MMBTU
B20 – B100 Boiler (<100 ppm @ 3% O2)	0.10 lb per MMBTU	0.10 lb per MMBTU
Combustion Turbine w/DLN or H2O (30 ppm @ 15% O2)	0.16 lb per MMBTU	0.25 lb per MMBTU
Steam Cycle Gas/Oil (200 ppm @ 3% O2)	0.25 lb per MMBTU	0.30 lb per MMBTU
Combustion Turbine w/o emissions control (150 ppm @ 15% O2)	0.80 lb per MMBTU	1.00 lb per MMBTU

## Conclusions

B50 and cold-climate heat pumps can have similar carbon intensity during moderate winter conditions.

Cold-climate heat pumps can show higher carbon intensity than ULSD under severe cold winter conditions but can achieve about 40% carbon savings over the entire heating season though with significant negative impact on grid operations and electricity cost for all classes of electric ratepayers.

B100 can achieve 80% carbon savings thus double the benefit of cold-climate heat pumps.

B100 remains the lowest carbon option for heating.

Thermal load-weighted ISO New England grid Marginal Emission Rates during winter are significantly higher than figures used by many policymakers for analysis of heat pump carbon savings.

Heat pump operation during winter peak periods can result in higher total NOx emissions than individual fuel-fired heating systems. One 350 MW combined-cycle unit (e.g., GE Series 7 HA Frame with HRSG) could heat 60,000 homes but would emit NOx equal to about 120,000 natural gas/Bioheat-fired home heating systems during 2 hr start-up period. Widely dispersed low-level area sources become Major point source re: USEPA Title 5 Clean Air Act emissions standards. Possible environmental justice concerns due to high local emissions in low-income neighborhoods adjacent to power plants.



**Biodiesel** - protecting our environment for future generations

Ray Albrecht, P.E.

NBB Technical Representative for Northeast US region

Member of ISO New England Planning Advisory Committee

rayalbrechtpe@gmail.com

(315) 382-6044 cell

**Supplemental Slides** 

## **Biodiesel Feedstocks for the Northeast**





- Recycled cooking oil
- Brown grease
- Soybean oil and Canola
- Pennycress and other winter cover crops gaining interest in agriculture
- Utilize existing wastes
- Improve market value for under-utilized coproducts and byproducts
- Diversity helps sustainability





# **Co-products of Food Production**

- Protein meal for livestock feed is the driver for soybean production and pricing
- Better utilization of the oil co-product can reduce the price of the protein meal.



## What is biodiesel?

Biodiesel is a renewable fuel, derived from natural oils, such as soybean oil, which meets the specifications of ASTM D 6751.

Biodiesel is not raw vegetable oil.

Biodiesel contains about 10 - 12 % oxygen in chemical structure.

Biodiesel has ultra-low sulfur and nitrogen contents.

Biodiesel can be blended with petroleum-based heating oil and used with little or no equipment modification.







## **Fuel Specifications – ASTM Standard D6751**

Property	Test Method <sup>4</sup>	Grade No. 1-8 S15	Grade No. 1-8 5500	Grade No. 2-8 515	Grade No. 2-8 5500
Sufur, <sup>#</sup> % mass (ppm), max	105452	0.0015 (15)	0.05 (500)	0.0015 (15)	0.05 (500)
Cold soak filerability, seconds, max	107501	200	200	360	200
Acnoglyceride content, % maxe, max	DESEA	0.40	0.40		
			Pequirements	for All Grades	
Taktum and Magnesium, combined, ppm (µg/g), max	EN 14538	5	5	5	5
Taah point (cloand cup), *C, min Vicohol control	093	93	90	93	90
One of the following shall be met:	EN MAND				0.7
<ol> <li>Methods content, mass A, mas</li> <li>Disab solid 30 min.</li> </ol>	1990	120	120	100	100
Z. Falan pont, 10, min	LONG	130	130	130	120
man and societies, 5 volume, max	19445	1960	1960	1960	19-60
inflated web. % many may	10074	0.020	0.020	0.020	0.020
opper strip corrosion, max	D130	No. 3	No. 3	No. 3	No. 3
Jelano number, min	0013	47	47	47	47
Doud point. <sup>#</sup> *C	102500	Fleport	Flaport	Fleport	Report
arbon residue," % mass, max	1048530	0.050	0.050	0.050	0.050
kid number, mg KOHig, max	10064	0.50	0.50	0.50	0.50
ne glycerin, % maxx, max	1000004	0.020	0.020	0.020	0.020
lotal glycarin, % mass, max	1000004	0.240	0.240	0.240	0.240
hosphorus content, % mass, max	D4851	0.001	0.001	0.001	0.001
Xetiliation temperature,	D1160	360	200	360	260
Atmospheric equivalent temperature, 90 % recovered, *C, max					
Sodium and Polassium, combined, ppm (µg/g), max	EN 14538	5	5	5	5
Oxidation stability, hours, min	EN 15751	9	2	9	3

<sup>8</sup> Other subtr limits may apply in selection areas in the United States and in other counties. <sup>6</sup> States interacting the states of the selection of the seatched by which performances at test temperatures at or bolow -12\*C shall comply with a cold scale. Illineability limit of 200 a maximum. <sup>6</sup> Sea K1.3.1, The 6.0 mm<sup>2</sup>/s apper viscosity limit in higher han patchism based dessit hall and should be balan into consideration when blending. <sup>8</sup> The could prior which is prevently higher than patchism based dessit hall and should be balan into consideration when blending. <sup>8</sup> The could prior which is prevently higher than patchism based dessit hall and should be balan into consideration when blending. <sup>8</sup> Cactors readius shall be run on the 100 % sample (see S.1.12).

- B100 specifications originally published in 1999 •
- 23 subsequent revisions •
- Over 20 minimum properties required for biodiesel vs 14 properties • for diesel fuel

## **Energy Characteristics of Biodiesel Production**

**Continuing Improvements in Biodiesel Production** 

**Total Life-cycle Energy Requirements for Soy-based Biodiesel** 



## **Biodiesel is Advanced Biofuel**

Authoring Agency	Year Published	GHG reduction compared to baseline petroleum
Argonne National Lab.	2017	66-72%
CARB	2015	50%
USDA	2012	76%
CARB	2011	12%
Argonne National Lab.	2011	73-90%
USEPA	2010	57%
Argonne National Lab.	2008	66-94%
USEPA	2008	22%
Nat. Renewable Energy Lab.	1998	78%

USEPA and CARB independently confirm LCA values for biodiesel including indirect land use change. GHG reductions will increase with further improvements in agriculture (e.g., no-till planting) also use of solar/wind power for processing and biodiesel for transport.

#### **Argonne National Laboratory Life-cycle Analysis of Biodiesel**



Carbon savings of about 80% and 66-72% total GHG savings depending on feedstock and including indirect land-use change (ILUC) based on current practices.



## **B100-fired Boilers – Opportunity for 100% Renewable Heating**



PHOTO A. A B100-fired boiler in a Brookhaven National Laboratory testing facility.



B20 blend is a drop-in fuel for residential and commercial boilers

**B100** can be implemented through basic technical modifications



## Exhibit 5-11: Summary Life-Cycle GHG Emissions Comparison for Residential and Commercial Boilers in New York City (kg CO<sub>2</sub>e/MMBtu)

Source: ICF Analysis.

## **Biodiesel – Pathway to a Sustainable Energy Future**

## **Providence Resolution**

September 2019

Industry Commitment to Renewable Fuel

Transition to B20 by 2023 will achieve 15% GHG savings

B50 by 2030 will achieve 40% GHG savings

Carbon-neutral by 2050 will achieve greater than 80% GHG savings



## **GE Power – Emissions Test Results for Biodiesel**

#### Blends with Oil and Co-firing with Natural Gas

Fuel	% GT Load	W/F w/w	NOx* (mg/Nm <sup>3</sup> )	O <sub>2</sub> *	CO* (mg/Nm <sup>3</sup>	CO <sub>2</sub> *	VOC* (mg/Nm <sup>3</sup> )	Bacharach No.
	2000		(	(,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	)	(/0/01)	(	1101
NG	100	0	247	15.4	< 1	3.26	1	0
DO	100	0	367	15.5	< 1	4.05	1	2.5
RME	100	0	360	15.3	<1	4.33	1	0 to 1
DO	100	0.20	102	15.0	<1	4.20	1	2.5
DO	100	0.30	198	15.2	<1	4.20	1	2.5
RME	100	0.43	161	15.1	1	4.51	-	0
20% RME / 80% NG	100	0	250	15.3	< 1	3.49	3	0
20% RME / 80% NG	100	0.5	105	15	1	3.67	3	0
500/ DME / 500/ NC	100	0	204	15.4	< 1	2.74	2	0
50% RME / 50% NG	100	0	294	15.4	< 1	3.74	2	0
70% RME / 30% NG	100	0	325	15.4	<1	3.92	1	0
70% RME / 30% NG	100	0.46	135	15.1	1	4.12	2	0
DME	75	0	247	16.1	1	3 39	2	0.5
RVIE D. F	75	0.24	247	10.1	1	3.36	2	0.5
KME	75	0.24	178	10.0	1	5.57	2	0
RME	50	0	166	17.6	5	2.65	3	0
50% RME / 50% DO	100	0	367	15.1	< 1	4.38	1.6	-

Table 5: Field Test emission results.

Lowest Nox levels achieved by co-firing with natural gas and biodiesel/water emulsion

## **Perspectives on Renewable Power Generation**



### Biodiesel-fired power generation in same general range of carbon intensity as other renewable energy sources